



Product Service

# CERTIFICATE


No. Z2 16 07 87632 004

**Holder of Certificate: Solar Juice Pty Ltd**10-12 Forsyth Close Wetherill Park  
Sydney NSW NSW 2164  
AUSTRALIA**Certification Mark:****Product:**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701261603301-00

Valid until: 2021-01-05



Date, 2016-07-11

( Zhulin Zhang )

Page 1 of 2



Product Service

**CERTIFICATE**

No. Z2 16 07 87632 004

**Model(s):**

OSR250P-60-S, OSR255P-60-S, OSR260P-60-S, OSR265P-60-S,  
OSR270P-60-S, OSR275P-60-S; OSR300P-72-S, OSR305P-72-S,  
OSR310P-72-S, OSR315P-72-S, OSR320P-72-S, OSR325P-72-S,  
OSR330P-72-S;

**Parameters:**

Rated Output Power  
at STC: 250W, 255W, 260W, 265W,  
270W, 275W; 300W, 305W,  
310W, 315W, 320W, 325W,  
330W;

Construction: Framed, with Junction box,  
Cable and Connectors.

Test Laboratory: Yangzhou Opto-Electrical  
Products Testing Institute;  
No. 10 West Kaifa Road, Yangzhou,  
225009 Jiangsu, P. R. China

Application Class: Class A  
Maximum System Voltage: 1000 V DC  
Fire Safety Class: Class C

**Tested  
according to:**

IEC 61215(ed.2)  
EN 61215:2005  
IEC 61730-1(ed.1);am1;am2  
EN 61730-1:2007/A2:2013  
IEC 61730-2(ed.1);am1  
EN 61730-2:2007/A1:2012

**Production  
Facility(ies):**

82429, 94163